

**BUREAU OF FIRE PREVENTION
TOWNSHIP OF OCEAN - FIRE DISTRICT 1
P.O. BOX 173, 72 LARKIN PL.
OAKHURST, NJ 07755**

**TIMOTHY J. SMITH
FIRE MARSHAL**

**OFFICE 732-222-2624
FAX 732-229-7326**

FIRE SAFETY REGULATIONS FOR FESTIVALS, FAIRS ETC.

JUNE 1998

*FIRE SAFETY REGULATIONS ARE ENFORCED BY THE BUREAU OF FIRE PREVENTION,
FIRE DISTRICT NO. 1.*

The regulations are as follows:

LPG (PROPANE) TANKS AND RELATED EQUIPMENT:

Maximum tank size shall be 100 pounds.

Regulators shall be located at the tank.

All tanks to have Warning Label reading "Flammable Gas", followed by the word PROPANE.

All hoses, fittings and clamps shall be listed for LPG use.

All tanks shall be secured by metal stakes and chains or other non-combustible type of securing devices.

No LPG tanks shall be located inside of tents or canopies.

All tanks shall be in good condition, not dented or rusted.

All tanks shall have up to date required tests.

Tanks shall be located a minimum of 6 feet from the cooking appliance.

The location of LPG tanks shall be checked by inspectors and any deemed unsafe shall be removed.

There shall be no more than two LPG TANKS at each location.

All LPG hoses shall be located as to prevent them from being damaged.

CANOPIES, TENTS AND BOOTHS:

All canopies on booths, or tent type booths shall be tested and Certified Flame Retardant - Proof Of Certification to be supplied.

Any wood booths shall be constructed of Fire rated lumber.

No plastic or fabric material canopies that are not certified Flame Retardant will be allowed.

FLAMMABLE AND COMBUSTIBLE LIQUIDS:

Gasoline shall be contained in an approved metal safety cans, maximum size of five (5) gallons.

All cans shall be red in color and properly marked "GASOLINE".

Kerosene containers shall be blue in color and marked "KEROSENE".

Gasoline and Kerosene containers shall be stored in a safe location, away from generators, LPG tanks, and cooking appliances.

When refueling generators or other appliances, they shall be shut off and refueled.

FIRE EXTINGUISHERS:

All booths shall have a minimum of one five pound ABC rated Fire Extinguisher with an up to date inspection tag.

If the inspectors determine that more than one extinguisher is required in a booth, the extinguisher shall be installed by the vendor.